

**CLASSIFICATION REPORT OF REACTION TO FIRE PERFORMANCE  
IN ACCORDANCE WITH EN 13501-1: 2018**

**Valid 5 years from the date of issue of this classification report**

## 1 Foreword

The product mentioned in this classification report is the object neither of a harmonized European standard, nor an European document of evaluation (EAD) leading to its CE marking, according to the European regulation n°305/2011 for construction product.

## 2 Introduction

This classification report defines the classification assigned to « **H7390 digitex decoflex WhiteNight** » (as described by the sponsor) in accordance with the procedure given in EN 13501-1: 2007 + A1: 2009

<b>Sponsor:</b>	<b>HEYTEX BRAMSCHE GMBH HEYWINKELSTR.1 D-49565 BRAMSCHE DEUTSCHLAND</b>
<b>Prepared by :</b>	<b>IFTH Avenue Guy de Collongue 69134 Ecully cedex – France</b>
<b>Name of product:</b>	<b>H7390 digitex decoflex WhiteNight</b>
<b>Classification report N° :</b>	<b>N° 19-02780 L</b>
<b>Issue number :</b>	<b>1</b>
<b>Date of issue :</b>	<b>November 8<sup>th</sup> 2019</b>

This classification report consists of four pages and may only be used or reproduced in its entirety.

Ce rapport de classement atteste uniquement des caractéristiques de l'échantillon soumis aux essais et ne préjuge pas des caractéristiques de produits similaires. Il ne constitue donc pas une certification de produits au sens de l'article L.115-27 du code de la consommation et de la loi du 3 juin 1994.

### 3 Details of classified product:

#### 3.1 General:

Product « H7390 digitex decoflex WhiteNight » (as described by the sponsor) is defined as a coated fabric printable for sign medium

#### 3.2 Description of the product:

Product « H7390 digitex decoflex WhiteNight » (as described by the sponsor), is described below or in the test report provided in support of classification listed in 3.1 :

100% polyester knitting with inherent flame retardant PU coating on one side

Nominal surface weight: 360 g/m<sup>2</sup>

Nominal thickness: 450 µm

Colour : White

### 4 This reports and results in support of classification:

#### 4.1 Reports :

Name of Laboratory	Name of Sponsor	Test report N°	Test method
IFTH Avenue Guy de Collongue 69134 ECULLY Cedex FRANCE	HEYTEX BRAMSCHE GMBH HEYWINKELSTR.1 D-49565 BRAMSCHE DEUTSCHLAND ALLEMAGNE	N° 19-02780 E1-V1 Dated on November 8 <sup>th</sup> 2019	NF EN ISO 11925-2:2013 NF EN 13823: 2013

#### 4.2 Test results :

Test method	Parameter	Nb. of Tests	Results	
			Continuous parameter mean	Compliance parameter
EN ISO 11925-2 Applied on the face 1 Time exposure 30s  Burning droplets or particles	F <sub>s</sub> ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO
EN ISO 11925-2 Applied on the slice Time exposure 30s  Burning droplets or particles	F <sub>s</sub> ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO
EN ISO 11925-2 Applied on the face 1 Time exposure 30s  Burning droplets or particles	F <sub>s</sub> ≤ 150mm in 60s	6	/	IN ACCORDANCE
	Ignition of paper		/	NO

Test method	Parameter	Nb. of Tests	Results	
			Continuous parameter mean	Compliance parameter
EN 13823* Face 1	FIGRA <sub>0.2MJ</sub> (w/s)	3	14.3	/
	FIGRA <sub>0.4MJ</sub> (w/s)		14.3	/
	THR <sub>600</sub> (MJ)		0.6	/
	LFS		/	NO REACH
	SMOGRA (m <sup>2</sup> /s <sup>2</sup> )		19.8	/
	TPS <sub>600s</sub> (m <sup>2</sup> )		73.3	/
EN 13823* Face 2	LDP <sub>f&lt;10s</sub>	3	/	NO
	LDP <sub>f&gt;10s</sub>		/	NO
	FIGRA <sub>0.2MJ</sub> (w/s)		0.0	/
	FIGRA <sub>0.4MJ</sub> (w/s)		0.0	/
	THR <sub>600</sub> (MJ)		0.3	/
	LFS		/	NO REACH
	SMOGRA (m <sup>2</sup> /s <sup>2</sup> )		24.7	/
	TPS <sub>600s</sub> (m <sup>2</sup> )		49.0	/
	LDP <sub>f&lt;10s</sub>		/	NO
	LDP <sub>f&gt;10s</sub>		/	NO

\*Specimen fixed on metallic frame with ventilated cavity 80 mm in width behind the sample according to the chapter 4.1.1.3-b of the standard EN 14716: 2005, sides the most remote from the angle and the spaces situated behind every wing being left opened.

## 5 Classification and field of application :

### 5.1 Reference of classification:

This classification has been carried out in accordance with EN 13501-1: 2018

### 5.2 Classification :

Product « **H7390 digitex decoflex WhiteNight** », in relation to fire behaviour is classified: **B**

The additional classification in relation to smoke product is: **s 2**

The additional classification in relation to flaming droplets / particles is: **d 0**

The format of the reaction to fire classification for construction products excluding flooring is:

Fire Behaviour		Smoke Production			Flaming Droplets	
<b>B</b>	-	<b>s</b>	<b>2</b>	-	<b>d</b>	<b>0</b>

**REACTION TO FIRE CLASSIFICATION : B- s2 - d0**

### 5-3 Field of application :

This classification is valid for the following product parameters :



Composition : 100% polyester knitting with inherent flame retardant PU coating on one side  
 Nominal surface weight : 360 g/m<sup>2</sup>  
 Nominal thickness : 450 µm  
 Colors : White

This classification is valid for the following end used application: advertising medium used hanging or starched, without substrate behind

**6 Limitation :**

This classification document does not represent type approval or certification of the product.

The test laboratory has played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

Report	Signatory	Signature*	Date
Edited by:	Olivier PALLAS Ingeneer Tests and Trials		November 8 <sup>th</sup> 2019
Approved by:	Sophie GUINAMAND In charge of Fire Regulation for Construction Products		November 8 <sup>th</sup> 2019
* For and in the name of I.F.T.H.			